

ArcSafe® T9 ArcFlash Switching Bib and Brace Trousers

ATPV 9 PPE 2 Orange

The ArcSafe® T9 Arc Switching Trousers are made from orange Tencate Tecasafe Plus with an ATPV 9 PPE 2. This classic fabric system is inherently flame resistant and provides protection against electrical arc flashes and flash fires.

T9 Materials

- Outer Fabric: Tencate Tecasafe Plus 251gsm

Features

- Classic T9 fabric system
- 50mm braces
- Hook + loop leg cuff closures
- Bar tacking for extra strength
- **OPTIONAL:** Added Reflective Trim: Class D/N



T9 Trousers	with Reflective Trim	Size
EASCTT9SML	EASCTT9T1SML	SML
EASCTT9MED	EASCTT9T1MED	MED
EASCTT9LRG	EASCTT9T1LRG	LRG
EASCTT9XLG	EASCTT9T1XLG	XLG
EASCTT92XL	EASCTT9T12XL	2XL
EASCTT93XL	EASCTT9T13XL	3XL

Product Data Sheet

Standards and Certification

- ASTM F2621-06 Standard Practice for Determining Response Characteristics and Design Integrity of Arc Rated Finished Products in an Electric Arc Exposure.
- T9 Garments comply with ENA NENS 09-2014 National Guideline for the Selection, Use and Maintenance of PPE for Electrical Arc Hazards – Arc Rated Garments and Hoods.
- Tecasafe Plus is UL Certified to NFPA 2112.
- T9 Fabrics meet the standards for NFPA70E and ASTM F1506.
- T9 Garments comply with AS4836:2011 – Safe working on or near low-voltage electrical installations and equipment.
- This garment with reflective trim added is certified to Australian Standard AS/NZS 4602.1:2011 High Visibility Safety Garments Class D/N by BSI.



PRODUCT CERTIFICATION



BSI Certified Product
AS/NZS 4602.1:2011
BMP No 739979



IMPORTANT

NFPA 70E Compliance requires wearing of the whole system (3-piece) as ONE UNIT. 3 Pieces including hood, coat and leggings or hood, jacket and bib & brace trousers. Once a garment has been exposed to an arc flash, it must be removed from service.